

EQUIPMENT TEST LIST

POWER PLANTS

1. GENERAL

1.01 This section provides the Equipment Test List for power plants (emergency operations Sections 002-502-914PT and 002-502-915PT).

1.02 It is reissued to change ETL requirements for the annual tests that are to be done by the local forces.

Note: Marginal arrows used to denote changes are omitted.

2. REQUIREMENTS

2.01 The audit and administrative items described in Section 002-502-914PT (Section C of Checklist) and the operation test Section 002-502-915PT (operation test) should be completed annually under direction of the district manager by the supervisor responsible for the office or the power equipment supervisor.

2.02 The annual audit check is mainly meant as a self-check for the office to ensure that important items concerning power equipment are being done. The annual operation test should be performed by local supervision and craft personnel without assistance from the power staff unless conditions exist that require their assistance.

2.03 The combined check list and operational tests outlined in Sections 002-502-914PT and 002-502-915PT is to be completed on a tri-annual basis (under the direction of the district manager) by the supervisor responsible for the office, with the assistance of the technical power staff group.

2.04 The check list and the operational tests are to be combined during the tri-annual operation test.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement

