

**MOTOR CONTROLLER KS-5647  
STARTER KS-15821  
REQUIREMENTS AND ADJUSTING PROCEDURES**

**1. GENERAL**

**1.001** This addendum supplements Section 024-345-701, Issue 3-D.

**1.002** This addendum is issued to specify the use of KS-19578 L1 trichloroethane wherever KS-8372 trichloroethylene is now specified. The same precautions that apply for KS-8372 trichloroethylene shall apply to the KS-19578 L1 trichloroethane.