

**AUTOTRANSFORMER-TYPE STARTERS  
AND COMPENSATORS  
GENERAL ELECTRIC COMPANY  
REQUIREMENTS AND ADJUSTING PROCEDURES**

**1. GENERAL**

**1.001** This addendum supplements Section 026-305-701, Issue 9-D.

**1.002** This addendum is issued to specify the use of KS-19578 L1 trichloroethane wherever KS-8372 trichloroethylene is now specified. The same precautions that apply for KS-8372 trichloroethylene shall apply to the KS-19578 L1 trichloroethane.