

**CONTACTORS**  
**KS-15514 AND KS-15934**  
**REQUIREMENTS AND ADJUSTING PROCEDURES**

**1. GENERAL**

1.001 This addendum supplements Section 026-360-701, Issue 3-D.

1.002 This addendum is issued to specify the use of KS-19578 L1 trichloroethane wherever KS-8372 trichloroethylene is now specified. The same precautions that apply for KS-8372 trichloroethylene shall apply to the KS-19578 L1 trichloroethane.