

**CONTACTORS, KS-5757, KS-15072, KS-15674 AND  
CONTACTORS HAVING NO KS- DESIGNATIONS  
ALLEN-BRADLEY COMPANY AND  
WESTINGHOUSE CORPORATION  
REQUIREMENTS AND ADJUSTING PROCEDURES**

**1. GENERAL**

**1.001** This addendum supplements Section 026-365-701, Issue 4-D.

**1.002** This addendum is issued to specify the use of KS-19578 L1 trichloroethane wherever KS-8372 trichloroethylene is now specified. The same precautions that apply for KS-8372 trichloroethylene shall apply to the KS-19578 L1 trichloroethane.