

**ENGINE FUEL
AND CARE OF FUEL TANKS
OPERATING METHODS**

1. GENERAL

1.001 This addendum supplements Section 065-320-301, Issue 7. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued to change the address of Renick & Mahoney, Inc., to add a reference to 7.13, and to specify the distance between the bottom of the storage tank and the bottom of the foot valve. This addendum does not affect the Equipment Test List.

2. CHANGES TO THE SECTION

2.001 On Page 2, under **TOOLS & MATERIALS**, change the address of Renick & Mahoney, Inc. from Roslyn Heights, L.I., N.Y. to 10 East Grand Boulevard, Deer Park, N.Y.

2.002 On Page 7, after the first sentence in 7.13, add: per 7.12.

2.003 On Page 9, after the last sentence in 9.05, add: This distance is approximately 3 inches.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement