

GENERAL CLEANING OF EQUIPMENT DUSTING AND WASHING OPERATIONS

1. GENERAL

1.001 This addendum supplements Section 069-305-301, Issue 3.

1.002 This addendum is issued to advise against the use of compressed air (pressure) for cleaning in ESS offices.

1. GENERAL

The following change applies to Part 1 of this section:

(a) 1.04—revised

1.04 It is assumed that the operations described in this section will be supplemented by vacuum or compressed air cleaning for local wiring forms and the more inaccessible points. However, compressed air (pressure) cleaning should not be attempted in ESS offices.