

## TOOLS

### FILLERS — DESCRIPTION

#### 1. GENERAL

1.01 This section covers noncoded Bell System filler tools.


1.02 This section is reissued to add KS-5499, L1402. The Equipment Test List is not affected.

1.03 The information contained in this section supersedes the corresponding information in Section 074-620-101.

1.04 For similar tools, see Cans, Section 074-208-105.

#### 2. DESCRIPTION OF TOOLS

**FILLER, BATTERY, E, EDELMANN & COMPANY, 74C**



Capacity: one gallon. Replacement part: 771 hose. For transporting water to, and filling, small central office batteries.


**FILLER, CELL, SYRINGE TYPE, KS-5499, L1400**

Replaced by the KS-5499, L1401 filler.

**FILLER, CELL SYRINGE TYPE, KS-5499, L1401 & 1402**


For use on KS-5361, L100, L110, L111, L112, L113, L114, and L115 batteries.

**FILLER, CELL, SYRINGE TYPE, WILLARD STORAGE BATTERY COMPANY, 90H**



For use on CTR-125 batteries.

**FILLER, CELL, COMMERCIAL (Obtain locally)**



Consists of a rubber stopper having a spout and airhole. To be mounted on a bottle of about 1 quart capacity. For use in adding distilled water to storage battery cells.

#### NOTICE

Not for use or disclosure outside the  
Bell System except under written agreement