

URGENT INFORMATION SUPPLEMENT  
JOB SPECIFICATION, "A" SECTION

Change 10.61 definition of term, "Retire in Place" to read:

Retire in Place	Equipment is retired and left in place. (This term is used only when specifically authorized by the Operating Telephone Company inasmuch as the price of the equipment so designated is removed from the Operating Telephone Company's Capital Account.)
--------------------	--

All switchboard cable originating from and termination on the frame, unit or position being retired in place is to be disconnected at far end only, i.e., distributing frames, fuse boards, other frames, unit or positions, etc. If switchboard cabling is covered by a separate wiring diagram figure or option, this figure or option should remain on the wiring list drawing. (With a note referenced to it stating what disconnections have been made at the far end.) If the equipments' "Far-end" circuit terminations are removed or retired in place, the work item need not include these terminations.

NOTE: The outside of local cable wiring of these circuits shall be removed by a separate work item or they shall be included in this work item and edited similar to the "Remove" work item.

- A. No change
- B. No change
- C. A note on the wiring list drawing shall be referenced against the retired-in-place equipment. The note shall indicate the circuits as being retired-in-place, any deviations from the normal retired-in-place condition.
- D. No change
- E. No change
- F. No change

Engineering Planning Manager  
(Installation)