

EQUIPMENT TEST LIST						
B.S.P.	ISS	TEST OR REQT.	EQUIPMENT AND WORK DESCRIPTION	CLASS	FREQ.	JOB NO.
			<b>SUPL 1</b>			
155-178-701	3		ENGINE ALTERNATOR KS15890 L1, 2, 3, & 4 (30, 45, 60, & 100KW - G.M. AUTOMATIC)			
			CHANGES			
(Page 35)		2.26	Check Voltage Regulator Output #each run-up if loaded	MW	#	
			Clean and Inspect Engine Control Cabinet Wiring Relays, and Switches	MW	12M	
			<b>SUPL 2</b>			
155-145-701	3		ENGINE ALTERNATOR KS5750— (20KW - G.M. AUTOMATIC)			
			ADDITION			
(Page 18)		3.21	Inspection of Louver Control Reservoir for Corrosion & Leakage	MW	6M	
155-145-702	3		ENGINE ALTERNATOR KS5750 (30, 40, & 60KW - G.M. AUTOMATIC)			
			ADDITION			
(Page 20)		3.21	Inspection of Louver Control Reservoir	MW	6M	
155-185-701	3		ENGINE ALTERNATOR KS15929 225KW L1, 2, 11, & 12 MANUAL & AUTOMATIC			
(Page 37)		2.01	Lubrication			
			DELETE			
			Throttle Solenoid Linkage	MW	M#	
			Fuel Rack, Solenoid Pivot Shaft	MW	M#	
		2.01	Lubrication			
			CHANGES			
			Lube Oil Filters (2.14)	MW	250H	
		2.35	Check Immersion Heater	MW	6M	
		2.46	Clean & Inspect Starting Motor & Sprag Clutch	MW	24M	
		2.47	Starting Solenoid Switch	MW	24M	
		2.49	Routine Run—3 Hours If Manually Operated	MW	W	
			ADDITIONS			
		2.16.1	Clean Inlet Bowl & Brass Screen on Lube Oil Level Regulator #or 300H engine operation	MW	6M#	

