

**AUTOMATIC SOLID-STATE CONTROL (J86634A)
FOR RESERVE DIESEL ENGINE-ALTERNATOR PLANTS
REQUIREMENTS AND ADJUSTING PROCEDURES**

1. GENERAL

1.001 This addendum supplements Section 155-020-701, Issue 2. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is reissued to add a note to remove CP12 for single engine application.

2. REQUIREMENTS

The following change applies to Part 2 of the section.

2.06— added note

2.06 *Reverse Power Detector (CP12):*

Note: CP12 was designed for parallel engine operation. For single engine operation, CP12

should be removed, at the option of the telephone companies, from the control cabinet.

3. ADJUSTING PROCEDURES

The following change applies to Part 3 of the section.

3.06— note added and note revised

3.06 *Reverse Power Detector (CP12)*(Req't 2.06):
Change original Note to Note 2.

Note 1: CP12 was designed for parallel engine operation. For single engine operation, CP12 should be removed, at the option of the telephone companies, from the control cabinet.