

ENGINE-ALTERNATORS—DIESEL
KS-15884, L1, L2, L3, L4 L12, L13, AND L14
30, 45, 60, AND 100 KW
MANUALLY CONTROLLED
REQUIREMENTS AND ADJUSTING PROCEDURES

1. GENERAL

1.001 This addendum supplements Section 155-176-701, Issue 5. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued to change the duration of the routine run made every 2

weeks. This addendum does not affect the Equipment Test List.

2. CHANGES TO SECTION

2.001 On Page 14, subparagraph 2.35(b), change "2 hours" to read "1 hour."

2.002 On Page 14, subparagraph 2.35(c), change "2-hour routine" to read "1-hour routine."

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement