

DISCHARGER-RECHARGER
KS-20770 L1 (LORAIN)
OPERATING METHODS

1. GENERAL

- 1.001** This addendum supplements Section 157-601-506, Issue 1.
- 1.002** This addendum is issued for the following reason.
- To add a warning and caution regarding the electrolyte level of lead-acid cells being discharged. This issue does not affect the Equipment Test List.

2. CHANGES TO SECTION

- 2.001** On Page 9, paragraph 4.01; change Warning to Warning 1, add Warning 2 as follows after Warning 1, and add the following caution after Caution 2.

Warning 2: Wear protective equipment such as rubber gloves, rubber aprons, and coverall goggles when performing any activity involving handling of electrolyte, cells containing electrolyte, or maintenance activities requiring exposure to shock or electrolyte contact from these cells.

Caution 3: If the electrolyte level of the cell to be discharged is at or near the high level mark on the jar, the electrolyte may overflow on recharge. It is recommended that, prior to start of test, electrolyte be removed to adjust the level approximately mid-way between the high and low level marks. The removed electrolyte can be replaced at the conclusion of the test.