

**KS-20336 L1 AIR DRYER
REQUIREMENTS
AND
ADJUSTING PROCEDURES**

1. GENERAL

1.001 This addendum supplements Section 161-308-701, Issue 1.

1.002 This addendum is issued to correct the recommended refrigerator temperature settings.

3. OPERATION

3.02 Change the last sentence to read as follows:

Additional moisture is removed as the air is cooled to approximately 40 to 42°F in the heat exchanger.

3.11 Change the first sentence to read as follows:

The refrigerated heat exchanger cools the air to approximately 40 to 42°F thereby removing additional moisture.

3.17 Change the last sentence to read as follows:

The refrigeration unit maintains the heat exchanger temperature at between 40 and 42°F.