

EQUIPMENT TEST LIST						
B.S.P.	I S S	TEST OR REQT.	EQUIPMENT AND WORK DESCRIPTION	CLASS	FREQ.	JOB NO.
167-731-301	1		RINGING AND TONE POWER PLANT 861A (J87812)			
(Page 9)		4.02	Adjustment of Power Failure Alarm	MW	6M	
		4.03	Adjustment of Tone Low-Voltage Monitors	MW	6M	
		4.04	1-VA Amplifier Adjustment	MW	12M	
		4.05	Adjustment of the 35-VA Dial Tone Amplifier	MW	12M	
			Distribution Fuse Alarm Checks			
		4.06	Fuse Alarms	MW	12M	
167-732-301	1		841A RINGING AND TONE POWER PLANT			
(Page 9)		4.02	-4.03 Check Oscillators	MW	6M	
		4.04	-4.05 Check Amplifiers	MW	6M	
		4.06	-4.07 Check Tone Monitors	MW	6M	
		4.08	-4.09 Check Power Failure Monitors	MW	6M	
		4.10	Check Pulsing Signal Output	MW	6M	
		4.11	Check Tone Signal Alarm	MW	6M	
		4.12	Check Interrupter Follow Relay	MW	6M	
		4.13	Check Distribution Circuit	MW	6M	
		4.14	Check Battery Distribution Fuse Alarm	MW	12M	
		4.15	Check Ringing Distribution Fuse Alarm	MW	12M	
167-725-317	1		807F (J87813) TONE POWER PLANT			
(Page 8)		4.04	Clean Ventilating Passages	MW	3M	
		4.05	Input Voltage Check	MW	M	
		4.06	Transfer and Alarm Check for Power Plants Used With Crossbar and Panel Systems	MW	6M	
		4.07	Transfer and Alarm Checks for Power Plants Used With Step-by-Step Systems	MW	6M	
		4.08	Amplifier Checks	MW	6M	
167-726-301	3		808A RINGING AND TONE POWER PLANT			
ADDENDUM	1	4.03	Delete			
(Page 8)						
167-770-301	4		J86474 POWER SUPPLY			
(Page 11)		1.03	Clean Ventilating Passages	MW	4M	
		4.01				
		(a)	Check Condition of Electron Tubes	MW	4M	
		4.02	Check Linear Magnetic Amplifiers and Metering Circuit Trip Points	MW	4M#	
			# And After TWT Replacement			
		4.03	Check Cooling Fan Operation	MW	4M#	

