

J86496 POWER SUPPLY
POSITIVE OR NEGATIVE 24-VOLT 0 TO 30 AMPERES
OPERATING METHODS

1. GENERAL

- 1.001** This addendum supplements Section 167-774-301, Issue 2.
- 1.002** This addendum is issued to change Paragraph 4.02(e).

4.02

- (e) *HLV Alarm*: Delete the next to last sentence. Delete: "In the negative plant," in the last sentence. The last sentence should read: Connect the GRD terminal of the 35-type test set to the positive terminal of the dry cell.

4. ROUTINE CHECKS

The following change applies to Part 4 of the section: