

EQUIPMENT TEST LIST
RECTIFIERS, KS-TYPE
POWER SYSTEMS EQUIPMENT

1. GENERAL

1.001 This addendum supplements Section 169-001-012, Issue 4.

1.002 It is issued to provide for more frequent testing of output switches on the KS-19792 L11 and L12 and KS-20040 L11 and L12 Rectifiers.

1.003 The present requirement of checking the output switches every 12 months is inadequate for proper maintenance of these switches.

28.0 RECTIFIERS, KS

- 28.57 — revised
- 28.60 — revised

28.57 RECTIFIERS, KS; KS-19792 L11, L12

FOR ALL UNITS

169-731-701 (2/0)	3.01 TEST COPPER S1 SWITCH	
	(1) VOLTAGE DROP ACROSS S1 SWITCH	MW 1M_____
	(2) TEMPERATURE CHECK ACROSS S1 SWITCH	MW 1M_____
	3.01 TEST SILVER PLATED SWITCH	
	(3) VOLTAGE DROP ACROSS S1 SW	MW 2M_____
	(4) TEMPERATURE CHECK OF S1 SW	MW 2M_____

28.60 RECTIFIERS, KS, KS-20040 L11, L12

FOR ALL UNITS

167-731-701 (2/0)	3.01 TEST COPPER S1 SWITCH	
	(1) VOLTAGE DROP ACROSS S1 SW	MW 1M_____
	(2) TEMPERATURE OF S1 SW	MW 1M_____
	3.01 TEST SILVER PLATED SWITCH	
	(3) VOLTAGE DROP ACROSS S1 SW	MW 2M_____
	(4) TEMPERATURE OF S1 SW	MW 2M_____

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement