

**J86249A, B, AND C RECTIFIERS
AND
J86249E L3 ELECTRONIC CONTROL
OPERATING METHODS**

1. GENERAL

1.001 This addendum supplements Section 169-618-305, Issue 3. Place this sheet ahead of Page 1 of the section.

1.002 This addendum is reissued to correct paragraph 4.05, Note 2 and to add a note to paragraph 5.05. This addendum does not affect the Equipment Test List.

1.003 Issue 1 of this addendum (replacing page addendum) was issued to revise 4.06 and to add 4.07.

1.004 Issue 2 of this addendum (replacing page addendum) was issued to add Note 2 to 4.05.

2. CHANGES TO SECTION

ISSUE 3 CHANGES

2.001 On Page 7, paragraph 4.05, Note 2 has been changed to read as follows.

Note 2: The KS-20522 controller has been developed to provide, in a solid state unit, the same functions as contacts in the ammeter relays. The controller contains no moving parts or heated filaments; therefore, it should provide more reliable service with less maintenance than the mechanical contacts. The KS-20522 controller is available as part of a modification kit which includes mounting hardware, wire, installation and wiring information, and, where required, some minor external components. There will be a modification kit available for several different applications. Refer to drawing J86741A-1 to ascertain the correct modification kit list number required for the particular application. For additional information, see Section 024-360-201 and SD 82023-01 and the corresponding circuit description.

2.002 On Page 10.1 add the following note.

Note: Use ZB option with the V-6 tubes which require extended range of (CCH) adjustment.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement