

**J86295A RECTIFIER**  
**48 VOLTS, 200 AMPERES**  
**VOLTAGE—REGULATED OUTPUT CONTROL**  
**23- OR 24-CELL OPERATION (REGULAR CELLS ONLY)**  
**OPERATING METHODS**

**1. GENERAL**

**1.001** This addendum supplements Section 169-630-301, Issue 5. Place this pink sheet ahead of Page 1 of the section.

**1.002** This addendum is issued to correct the initial setting of two controls in the Current Limit Circuit check. This addendum does not affect the Equipment Test List.

**2. CHANGE TO SECTION**

**2.001** On Page 6, step 2 of 4.04, change the initial setting of the CON CUR-H and CON CUR-L potentiometers as follows:

CON CUR-H potentiometer fully cw

CON CUR-L potentiometer fully cw

**NOTICE**

Not for use or disclosure outside the  
Bell System except under written agreement