

KS-19211, L2 AND L7, RECTIFIERS
24 VOLTS, 800 AMPERES
OPERATING METHODS

1. GENERAL

1.001 This addendum supplements Section 169-709-301, Issue 3. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued for the following reasons:

- (a) To add a note referencing the KS-20522 controller
- (b) To revise paragraph 5.01
- (c) To delete paragraphs 5.02 through 5.06.

This addendum does not affect the Equipment Test List.

2. CHANGES TO SECTION

2.001 On the bottom of Page 1, delete the Copyright Notice and add the following:

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement

2.002 On Page 2, add the following note to paragraph 1.10:

Note: The KS-20522 controller has been developed to provide, in a solid-state unit, the same functions as contacts in the ammeter relays. The controller contains no moving parts or heated filaments; therefore, it should provide more reliable service than the mechanical contacts. The KS-20522 controller is available as part of a modification kit which includes mounting hardware, wire, installation and wiring information, and, where required, some minor external components. There will be a modification kit available for several different applications. For additional information, see Section 024-360-201 and SD-82023-01 and the associated circuit description.

2.003 On Page 7, change paragraph 5.01 to read:

5.01 For Trouble Analysis, refer to Section 169-709-311.

2.004 On Pages 7 through 9, delete paragraphs 5.02 through 5.06.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement