

**KS-19211, L3, RECTIFIER**  
**24 VOLTS, 800 AMPERES**  
**OPERATING METHODS**

**1. GENERAL**

**1.001** This addendum supplements Section 169-710-301, Issue 2. Place this pink sheet ahead of Page 1 of the section.

**1.002** This addendum is issued for the following reasons:

- (a) To add a note referencing the KS-20522 controller
- (b) To revise paragraph 5.01
- (c) To delete paragraphs 5.02 through 5.06.

This addendum does affect the Equipment Test List.

**2. CHANGES TO SECTION**

**2.001** On the bottom of Page 1, delete the Copyright Notice and add the following:

**NOTICE**

Not for use or disclosure outside the  
Bell System except under written agreement

**2.002** On Page 2, add the following note to paragraph 1.11:

**Note:** The KS-20522 controller has been developed to provide, in a solid-state unit, the same functions as contacts in the ammeter relays. The controller contains no moving parts or heated filaments; therefore, it should provide more reliable service than the mechanical contacts. The KS-20522 controller is available as part of a modification kit which includes mounting hardware, wire, installation and wiring information, and, where required, some minor external components. There will be a modification kit available for several different applications. For additional information, see Section 024-360-201 and SD-82023-01 and the associated circuit description.

**2.003** On Page 5, change paragraph 5.01 to read:

**5.01** For Trouble Analysis, refer to Section 169-710-311.

**2.004** On Pages 5 and 6, delete paragraphs 5.02 through 5.06.

**NOTICE**

Not for use or disclosure outside the  
Bell System except under written agreement