

KS-19211, L4 AND L9, RECTIFIERS
24 VOLTS, 800 AMPERES
OPERATING METHODS

1. GENERAL

1.001 This addendum supplements Section 169-711-301, Issue 2. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued for the following reasons:

- (a) To add a note referencing the KS-20522 controller
- (b) To revise paragraph 5.01
- (c) To delete paragraphs 5.02 through 5.06.

This addendum does affect the Equipment Test List.

2. CHANGES TO SECTION

2.001 On Page 1, add the following note to paragraph 1.10:

Note: The KS-20522 controller has been developed to provide, in a solid-state unit, the same functions as contacts in the ammeter relays. The controller contains no moving parts or

heated filaments; therefore, it should provide more reliable service than the mechanical contacts. The KS-20522 controller is available as part of a modification kit which includes mounting hardware, wire, installation and wiring information, and, where required, some minor external components. There will be a modification kit available for several different applications. For additional information, see Section 024-360-201 and SD-82023-01 and the associated circuit description.

2.002 On the bottom of Page 1, delete the Copyright Notice and add the following:

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement

2.003 On Page 9, change paragraph 5.01 to read:

5.01 For Trouble Analysis, refer to Section 169-711-311.

2.004 On Pages 10 and 11, delete paragraphs 5.02 through 5.06.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement