

KS-19212, L3 AND L4, RECTIFIERS
24 VOLTS, 1600 AMPERES
OPERATING METHODS

1. GENERAL

1.001 This addendum supplements Section 169-713-301, Issue 3. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued to add a note referencing the KS-20522 controller.

This addendum does not affect the Equipment Test List.

2. CHANGES TO SECTION

2.001 On Page 2, add the following note to paragraph 1.04:

Note: The KS-20522 controller has been developed to provide, in a solid-state unit, the same function as contacts in the ammeter relays. The controller contains no moving parts or heated filaments; therefore, it should provide more reliable service than the mechanical contacts. The KS-20522 controller is available as part of a modification kit which includes mounting hardware, wire, installation and wiring information, and, where required, some minor external components. There will be a modification kit available for several different applications. For additional information, see Section 024-360-201 and SD-82023-01 and the associated circuit description.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement