

**KS-20489 RECTIFIERS**  
**48 VOLTS, 400 AMPERES**  
**OPERATING METHODS**

**1. GENERAL**

**1.001** This addendum supplements Section 169-741-301, Issue 2. Place this pink sheet ahead of Page 1 of the section.

**1.002** This addendum is issued to make a necessary change to the procedure of placing the rectifier in the test mode of operation. This addendum does not affect the Equipment Test List.

**2. CHANGES TO SECTION**

**2.001** On Page 7, after Step 4, add Step 5 as follows: Charge the filter capacitors in accordance with the first three steps of 3.06.

**Note 1:** Any external loads shall be in the OFF position.

**Note 2:** After the capacitors are charged, the switch in the charging circuit shall be turned off.

**Note 3:** This procedure is to be followed whenever the rectifier has not been operating for longer than 30 seconds.

**2.002** The present Steps 5 through 11 become Steps 6 through 12, respectively.

**NOTICE**

Not for use or disclosure outside the  
Bell System except under written agreement