

KS-21113, L1 AND L2, RECTIFIERS
ITT—NORTH ELECTRIC COMPANY
140 VOLTS, 200 AMPERES
OPERATING METHODS

1. GENERAL

1.001 This addendum supplements Section 169-746-302, Issue 2. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued to delete the last sentence of subparagraph 3.02(1).

2. CHANGES TO SECTION

2.001 On pages 3 and 4, change subparagraph 3.02(1) to read:

(1) Connect the KS-21113 dummy load, supplied with the plant, to terminals E23 and E24 of the rectifier. It is not necessary to observe polarity.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement