

CENTRAL OFFICE AND PABX LEAD-ACID BATTERIES

General Information

1. GENERAL

1.01 This addendum to Section 205-005-040, Issue 4, changes the corrected specific gravity from 1.026 to 1.206.

1.02 in ink or red pencil, make the changes indicated in part 2 or write "See Addendum" in the margin adjacent to the

change. File this addendum directly in front of the addended section.

2. CHANCES

2.01 Paragraph 5.08, top of page 6 change the corrected specific gravity from 1.026 to 1.206 and (1.028 - 0.002) to (1.208 - 0.002).