

FLOOR-MOUNTED STORAGE BATTERY CELLS  
'ENCLOSED TYPE  
INSTALLATION

**1. GENERAL**

**1.01** This addendum to Section 205-005-201, Issue 1, adds a note referring the user to appropriate sources of information about specific equipment, installation, operation, and maintenance requirements.

**1.02** Changes described in issue 1 of this addendum are also included in this issue. Issue 2 changes are indicated by underlined paragraph numbers.

**1.03** Microfiche Copy Recipients. Remove Issue 1 of this section from the file and replace it with the microfiche copy identified as Issue 1, addendum 2. Changes are marked in the replacing copy.

**1.04** Paper Copy Recipients. In ink or red pencil, make the changes indicated in part 2 or write "See Addendum" in the margin adjacent to the changed information. Discard Addendum 1 and file this addendum in front of Section 205-005-201, Issue 1.

**2. CHANGES**

**2.01** Following paragraph 1.01, add the

following note:

**NOTE:** Because equipment installation, operation, and maintenance requirements differ from manufacturer to manufacturer, and because individual manufacturers frequently change their specifications, this section is only intended to be generic. For specific installation, operation, and maintenance requirements, refer to the documentation provided by the manufacturer of the equipment in question.

**2.02** In paragraph 4.02, change "fiberborad" to "fiberboard."

**2.03** In paragraph 5.04, change "data-due-for-charge" to "date-due-for-charge."

**2.04** Following paragraph 7.03, delete the note and replace it with the following note:

**NOTE:** Tighten the bolts to a torque of 110 inch-pounds.