

EQUIPMENT TEST LIST
MISCELLANEOUS FUSE ALARMS
NO. 4A AND 4M TOLL SWITCHING SYSTEMS

	CONTENTS	PAGE
1. GENERAL	1
14.1	ALT RTE TRF CNT	2
14.2	TRAFFIC CNTRL CK	2
14.3	NETWORK CONTROL	2
14.4	TBL RCDR FRAME	2
14.5	SNDR MAKE BSY FR	2
14.6	SNDR TRF CONT CK	2
14.7	CBA TRUNK FRAME	2
14.8	MISC RELAY RACKS	2
14.9	MISC FUSE BAY	2
14.10	BILLING DATA TRANS	2

applicable to equipment listed in the preceding table of contents. Test classification and frequency of periodic routine are also provided.

1.02 This Equipment Test List (ETL) is reissued to incorporate changes which are indicated by an arrow to the left of each line which has been changed.

1.03 Comments on this section should be made by following the instructions in Bell System Practices (BSP), Section 000-010-015.

1.04 Routine test information is arranged in the following order from left to right: Section number, issue/addendum, test letter or paragraph number, test title, test class, frequency, and the last space is for a locally assigned job number.

1.05 Section 010-300-011 provides Equipment Test List instructions.

1. GENERAL

1.01 This section provides an index and information access system to locate the standard tests

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement

14.0 MISC FUSE ALARMS

14.1 MISC FUSE ALARMS; ALT RTE TRF CNT

FOR ALL UNITS

212-330-501 (10/0) M ALT RTE TRAFFIC CONT FRAME MR 12M -----

14.2 MISC FUSE ALARMS; TRAFFIC CNTRL CK

FOR ALL UNITS

212-330-501 (10/0) N TRAFFIC CONTROL CIRCUIT MR 12M -----

14.3 MISC FUSE ALARMS; NETWORK CONTROL

FOR ALL UNITS

212-330-501 (10/0) AW NETWORK CONTROL MR 12M -----

14.4 MISC FUSE ALARMS; TBL RCDR FRAME

FOR ALL UNITS

212-330-501 (10/0) AG MISC CKT TBL RECORDER FRAME MR 12M -----

14.5 MISC FUSE ALARMS; SNDR MAKE BSY FR

FOR ALL UNITS

212-330-501 (10/0) AA MISC CKT SDR MAKE-BUSY FRAME MR 12M -----

14.6 MISC FUSE ALARMS; SNDR TRF CONT CK

FOR ALL UNITS

212-330-501 (10/0) V SENDER TRAFFIC CONTROL CIRCUIT MR 12M -----

14.7 MISC FUSE ALARMS; CBA TRUNK FRAME

FOR ALL UNITS

212-330-501 (10/0) X CKT BUSY ANCMT TRUNK FRAME MR 12M -----

14.8 MISC FUSE ALARMS; MISC RELAY RACKS

FOR ALL UNITS

212-330-501 (10/0) Y MISC CKT FOR RELAY RACK BAYS AND TRUNK FRAMES MR 12M -----

14.9 MISC FUSE ALARMS; MISC FUSE BAY

FOR ALL UNITS

212-330-501 (10/0) Z MISCELLANEOUS FUSE BAY MR 12M -----

14.10 MISC FUSE ALARMS; BILLING DATA TRANS

FOR ALL UNITS

212-330-501 (10/0) CF MISC CKT FOR BILL. DATA TRANS MR 12M -----