

CENTRAL OFFICE  
ERECTION METHODS

1. GENERAL

1.01 This addendum to Section 237-050-204, Issue 5, is issued to change paragraph 9.04.

1.02 Microfiche Copy Recipients. Remove Issue 5 of this section from the file and replace it with the microfiche copy identified as Issue 5, Addendum 1.

1.03 Paper Copy Recipients. In ink or red pencil, make the changes indicated in part 2 of this addendum. Write "See Addendum" in the margin next to the change. File this addendum directly in front of the addended practice.

2. CHANGES

2.01 Change paragraph 9.04 to read as follows:

All central office equipment is to be protected by using guardrails or their equivalent. Should cable, wire, protectors, terminal blocks, loop extenders, or other equipment extend beyond the guardrails (or if guardrails do not exist), contact the Engineering Department immediately for corrective action to prevent a potential hazard from developing.