

PROCEDURES FOR CROSS-CONNECTING (JUMPERING)  
CENTRAL OFFICE DISTRIBUTING FRAMES

1. GENERAL

1.01 This addendum is issued to add two-conductor jumper wire for control leads to Section 256-150-200, Issue 2. With ink or red pencil make the changes indicated in Part 2. File this addendum immediately in front of Section 256-150-200, Issue 2.

2.02 Change paragraphs 2.03 through paragraph 2.06 to read 2.04 through 2.07, respectively.

2.03 Add new paragraph 2.03. "Two-conductor jumpers of blue and black should be used when it becomes necessary to separate transmission from control leads."

2. CHANGES

2.01 Immediately following paragraph 2.01, replace Table 1 with the following table.

Table 1. Color Code For Standard Jumper Wire.

JUMPER WIRE	TIP (+)	RING (-)	CONTROL (C)	EXTRA CONTROL (EC)
2-CONDUCTOR	WHITE	RED	—	—
2-CONDUCTOR	—	—	BLUE	BLACK
3-CONDUCTOR	WHITE	RED	BLUE	—
4-CONDUCTOR	WHITE	RED	BLUE	BLACK
4-CONDUCTOR	WHITE	BLACK	RED(+)	GREEN(-)
(QUAD)	SEE PARAGRAPH 2.06			