

## SUBSCRIBER LOOP CARRIER 1 (SLC\*-1) SYSTEM CENTRAL OFFICE INSTALLATION AND TESTING

### 1. GENERAL

1.001 This addendum supplements Section 363-400-300, Issue 1. Place this pink sheet ahead of Page 1 of the section.

1.002 This addendum is issued to add information on selecting a mounting location for the SLC-1 CO shelf.

### 2. CHANGES TO SECTION

2.001 Paragraph 2.02 beginning on Page 1 should be changed to read as follows: When

selecting a mounting location for the SLC-1 CO shelf (J98729B), consideration must be given to noise generated by other CO equipment. Locations less than four feet from RF noise generators such as certain dc-to-dc converters should be avoided. Locations in bays containing or adjacent to switching equipment or within two feet of a D channel bank power supply should also be avoided. All CO shelf units may be located side by side to provide a centralized installation. The length of the shelf cabling to the HMDF is not critical, but the cable must be shielded.

\*Trademark of the Western Electric Company.

### NOTICE

Not for use or disclosure outside the  
Bell System except under written agreement