

AUXILIARY SIGNALS IDENTIFICATION

1. GENERAL

- 1.01 This addendum supplements Section 463-110-100 and is issued to provide information on customer provided power outlets.
- 1.02 This addendum has been issued to delete information contained in Paragraph 3.07 and expand on customer responsibility in placing weatherproof power outlets.

2. INSTALLATION

- 2.01 Prior to installation, Marketing or Commercial shall make a definite agreement with the customer covering the provisions of any necessary power wiring, and the procurement of a weatherproof power outlet box.
- 2.02 When required, the customer must provide a weatherproof 15 ampere, 125V, Hubbell 5620 (or equivalent) outlet box equipped with a threaded cover plate, to receive a standard 3-prong plug with "U" ground. The outlet must be mounted within four feet of the signal location.