

**10A ALERTING SYSTEM  
PERIODIC MAINTENANCE  
AND OVERALL TESTS**

**1. GENERAL**

**1.001** This addendum supplements Section 480-316-501, Issue 2.

**1.002** This addendum is issued to advise that a yearly inspection and adjustment of the PG, P, and LP relays of the code sending and code receiving circuit SD-1G214-01 is required.

The following change applies to Part 1 of the Section:

(a) 1.08—revised.

**1.08** Tests A through F are periodic tests which are performed at the time of initial installation and at 6-month intervals. Tests G through H are operational tests which may be performed at any time. Tests I through AA are initial installation tests which are performed at the time of initial installation. Inspection and adjustment of the PG and P relays of the code sending unit SD-1G214-01 Fig. 1, and the LP relay of the code receiving unit SD-1G214-01 Fig. 2, are made at the time of initial installation and at 12 month intervals. Refer to circuit notes 105 and 108 of SD-1G214-01 for inspection and adjustment requirements of the relays.