

ELECTRIC GROUNDING AND WIRING REQUIREMENTS

BOOTHS - METAL

1. GENERAL

- 1.001 This addendum supplements Section 508-100-100, Issue 2.
- 1.002 This addendum is issued to revise the connection of a booth to the power circuit.
- 1.003 Delete the information in 2.03 and substitute the following:
- 2.03 No. 14 AWG conductors are used for electrical wiring of metal booths. A 15 ampere fuse

or circuit breaker should be located in the power circuit to the booth except:

- (a) A cord and plug-connected booth may be connected to a 20-ampere branch circuit protected with a fuse or circuit breaker.
- (b) The booth power receptacle may be permanently wired to a 20-ampere branch circuit protected with a fuse or circuit breaker, using No. 12 AWG conductors, provided the booth is not the sole device on the branch circuit and no external devices are permanently wired to the booth power receptacle with less than No. 12 AWG wire.