

BOOTHS-UNIVERSAL
(INDOOR-OUTDOOR) KS-16797
IDENTIFICATION

1. GENERAL

1.001 This addendum supplements Section 508-230-100, Issue 3.

1.002 This addendum is issued to change the part number of the double-pole single throw circuit breaker which is installed in the junction box.

6. JUNCTION BOX (Fig. 4)

The following supplemental information applies to Part 6 of the section:

(a) 6.02—revised

6.02 A double-pole single throw circuit breaker may be installed in the junction box if required. The circuit breaker must be ordered separately from Heinemann Electric Co., *No. 2912, 10 amp, 120 volts ac, Curve 3.*