

BOOTHS - OUTDOOR - KS-14611

ELECTRIC WIRING AND GROUNDING REQUIREMENTS

1. GENERAL

1.01 This addendum is issued to change requirements for the driven grounding device.

1.02 Change: Paragraph 4.01, last line to read:

"Otherwise a driven ground rod must be provided at the booth and connected to the booth."

Change: Paragraph 4.02 to read:

The ground rod shall be driven at least 5 feet into moist earth with the top 3 inches below the surface.