

PRECAUTIONS
GROUNDING PORTABLE ELECTRIC TOOLS

1. GENERAL

- 1.001** This addendum supplements Section 620-103-010.
- 1.002** It is reissued to change paragraph numbers to agree with the main section.

The following change applies to Part 1 of the section:

1.03 — NOTE revised

Note: Tools operated from ungrounded portable electric generators (circuit isolated from ground) do not require earth grounding. However, the frames of all portable tools must be bonded to the generator frame for additional safety. Therefore, all generators should be equipped with grounding type outlets.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement

Printed in U.S.A.