REPLACING PAGE ADDENDUM
Filing Instructions:

1. REMOVE FROM THE SECTION THE PAGES NUMBERED THE SAME AS THOSE ATTACHED TO THIS PINK SHEET.
2. INSERT THE ATTACHED PAGES INTO THE SECTION IN THEIR PLACE.
3. PLACE THIS PINK SHEET AHEAD OF PAGE 1 OF THE SECTION.

ADDENDUM 627-070-017
Issue 1, April 1968
AT&TCo Standard

CLEARANCES FOR AERIAL CABLE AND GUYS INSTALLED IN THE HEAVY LOADING AREA

1. GENERAL

1.001 This addendum supplements Section 627-070-017, Issue 1. The attached pages must be inserted in the section in accordance with the filing instructions above.

Attached:

Page 11 dated April 1968, revised

Page 12 dated April 1968, reissued

1.002 This addendum is issued to revise the heading of Table 5 to include: cables weighing 1/2 to 1 lb/ft.

©American Telephone and Telegraph Company, 1967 1968
Printed in U.S.A.

TABLE 5—LONG SPAN CABLE ON 10M AND 16M CROSSING OR OVERHANGING ROADS, ALLEYS AND DRIVEWAYS—CABLES WEIGHING 1/2 TO 1 LB/FT

	CROSSING OVER						RUNNING ALONG PUBLIC ROADS		
	PUBLIC ROADS		PUBLIC ALLEYS		RES. DRIVE				
Span Length	Generally	Pole within 100 feet of far edge (See Fig. 1)	Generally	Pole within 100 feet of far edge (See Fig. 1)	Generally	Pole within 100 feet of far edge (See Fig. 1)	Major Overhang (See Fig. 2) Urban or Rural Areas	Minor Overhang (See Fig. 2) Urban Areas	Minor Overhang Rural Areas
FEET	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.
For Cables Supported on 10M Strand									
301/333	18- 5	18- 0	15- 5	15- 0	10- 5	10- 0	18- 5	18- 0	14- 0
334/366	18-10	18- 1	15-10	15- 1	10-10	10- 1	18-10	18- 0	14- 0
367/400	19- 3	18- 2	16- 3	15- 2	11- 3	10- 2	19- 3	18- 0	14- 0
401/433	19- 8	18- 4	16- 8	15- 4	11- 8	10- 4	19- 8	18- 0	14- 0
434/466	20- 2	18- 6	17- 2	15- 6	12- 2	10- 6	20- 2	18- 2	14- 2
467/500	20- 8	18- 8	17- 8	15- 8	12- 8	10- 8	20- 8	18- 8	14- 8
501/533	21- 2	18- 9	18- 2	15- 9	13- 2	10- 9	21- 2	19- 2	15- 2
534/566	21- 8	18-10	18- 8	15-10	13- 8	10-10	21- 8	19- 8	15- 8
For Cables Supported on 16M Strand									
333/366	18- 5	18- 0	15- 5	15- 0	10- 5	10- 0	18- 5	18- 0	14- 0
367/400	18-10	18- 0	15-10	15- 0	10-10	10- 0	18-10	18- 0	14- 0
401/433	19- 3	18- 0	16- 3	15- 0	11- 3	10- 0	19- 3	18- 0	14- 0
434/466	19- 8	18- 2	16- 8	15- 2	11- 8	10- 2	19- 8	18- 0	14- 0
467/500	20- 1	18- 3	17- 1	15- 3	12- 1	10- 3	20- 1	18- 1	14- 1
501/533	20- 6	18- 4	17- 6	15- 4	12- 6	10- 4	20- 6	18- 6	14- 6
534/566	20-11	18- 5	17-11	15- 5	12-11	10- 5	20-11	18-11	14-11
567/600	21- 4	18- 6	18- 4	15- 6	13- 4	10- 6	21- 4	19- 4	15- 4

TABLE 6—LONG SPAN CABLE ON 10M AND 16M CROSSING OR OVERHANGING ROADS, ALLEYS AND DRIVEWAYS—CABLES WEIGHING OVER 1 LB/FT

	CROSSING OVER							RUNNING ALONG PUBLIC ROADS	
	PUBLIC ROADS		PUBLIC ALLEYS		RES. DRIVE				
Span Length	Generally	Pole within 100 feet of far edge (See Fig. 1)	Generally	Pole within 100 feet of far edge (See Fig. 1)	Generally	Pole within 100 feet of far edge (See Fig. 1)	Major Overhang (See Fig. 2) Urban or Rural Areas	Minor Overhang (See Fig. 2) Urban Areas	Minor Overhang Rural Areas
FEET	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.	FT. IN.
Cables Weighing from 1 to 2 lb/ft—10M Strand									
339 less	18- 0	18-0	15- 0	15-0	10- 0	10-0	18- 0	18-0	14-0
340 400	18- 8	18-0	15- 8	15-0	10- 8	10-0	18- 8	18-0	14-0
401 460	19- 4	18-0	16- 4	15-0	11- 4	10-0	19- 4	18-0	14-0
Cables Weighing from 1 to 2 lb/ft—16M Strand									
374 less	18- 0	18-0	15- 0	15-0	10- 0	10-0	18- 0	18-0	14-0
375 425	18- 6	18-0	15- 6	15-0	10- 6	10-0	18- 6	18-0	14-0
426 475	19- 1	18-0	16- 1	15-0	11- 1	10-0	19- 1	18-0	14-0
476 525	19- 7	18-0	16- 7	15-0	11- 7	10-0	19- 7	18-0	14-0
526 550	19-10	18-0	16-10	15-0	11-10	10-0	19-10	18-0	14-0
Cables Weighing over 2 lb/ft—10M Strand									
385 less	18- 0	18-0	15- 0	15-0	10- 0	10-0	18- 0	18-0	14-0
Cables Weighing over 2 lb/ft—16M Strand									
425 less	18- 0	18-0	15- 0	15-0	10- 0	10-0	18- 0	18-0	14-0
426 450	18- 3	18-0	15- 3	15-0	10- 3	10-0	18- 3	18-0	14-0