
BIX*

In-Building Cross-Connect System
Material Installation and Servicing
(Wall-Mounted System)

Publication number: 631-4511-200 Addendum

Document Status: Standard

Date: 81 12 01

-

© Northern Telecom Limited 1981

*BIX is a trademark of Northern Telecom Limited

General

- 1.001 This addendum supplements 631-4511-200.
- 1.002 This addendum is issued to add information on electrical protection requirements for the BIX cross-connect systems.
- 1.03 BIX hardware is intended for use in terminating and cross-connecting telephone system conductors. All installations of BIX hardware must meet the electrical protection requirements as prescribed by the applicable codes. Electrical protection, where required, must be installed between the exposed conductors and the BIX cross-connect hardware.

BIX*
In-Building Cross-Connect System
Material Installation and Servicing
(Wall Mounted Systems)

© 1981 Northern Telecom
All rights reserved.
Information subject to change without notice.
Standard
81 12 01
Printed in Canada.

