

NEW EQUIPMENT—BUILDING SYSTEM (NEBS) IN NEW BUILDINGS

CONTENTS	PAGE
1. GENERAL	1
2. STANDARD CENTRAL OFFICE BUILDING	1
A. Floor-to-Ceiling Height	1
B. Building Bay Dimensions	1
C. Column Size	2
D. Cable Holes	2
3. CENTRAL OFFICE DESCRIPTION	2
A. Equipment Frame Area	2
B. Power Areas	8
C. Distributing Frame Area	11
D. Cable Entrance Area	11
E. Equipment Hoisting Area	12
4. REFERENCES	13
5. SUMMARY OF NEBS STANDARDS	14

1. GENERAL

1.01 This section provides an overall description of the New Equipment—Building System (NEBS) and provides standards for use in the design of new buildings or building additions that are intended to house telephone equipment that meets the requirements of Section 800-610-164, "NEBS—General Equipment Requirements" or Technical Reference PUB 51001 for general trade equipment.

1.02 This practice supercedes Section 4.1 of Specification X-74300, "NEBS Building Engineering Standards (BES)." Whenever this

section is reissued, the reason for reissue will be listed in this paragraph.

2. STANDARD CENTRAL OFFICE BUILDING

2.01 To gain flexibility and to realize specific cost savings, all telephone central office buildings shall be built to system standards. Buildings will vary in many ways, such as overall size, physical appearance, and architectural details, but a few features are identical. These standard features, which are listed below, are the basis of the new standard central office buildings.

Top of floor slab to bottom of lowest structural member	12-1/2 ft
Equipment systems floor live load (including transient load)	150 psf
Building bay size	20 × 20 ft
Cable holes	three between each pair of columns in all column rows parallel to equipment frame lineups

A. Floor-to-Ceiling Height

2.02 Within the space between the top of the slab and the bottom of the lowest structural member, a 10-foot clearance is reserved for equipment frames and cable. The remaining height is primarily for the building system, such as air ducts, lights, and the Modular (high-capacity) Cooling System (MCS). The MCS option is used where high equipment heat dissipation occurs over large floor areas. The MCS is described in the following pages and in Section 760-550-300.

B. Building Bay Dimensions

2.03 Optimum building column spacing is a compromise between wide spacing, which

results in less interference with the equipment, and close spacing which permits lighter floor construction and more slender columns (see Section 760-200-100). Studies have shown that with floor live loads of 150 psf, minimum costs occur with column spacing ranging between 15 and 25 feet for concrete construction and below 25 feet for steel construction (see Fig. 1).




Fig. 1—Building Cost as a Function of Column Spacing. These costs are associated with a floor live load of 150 psf for a three-story structure.

2.04 Modular dimensions recommended by the American National Standards Institute are 4 inches and 4 feet. The use of these dimensions, or multiples of them, increases the adaptation of standard commercial building construction techniques to telephone equipment buildings and enables the use of standard materials and components.

2.05 Equipment aisle widths and frame depths also influence the selection of building bay dimensions. Equipment systems must fit reasonably within the standard building space. Floor plans developed for the full variety of equipment intended for central office installation show that 20-foot-square building bays are entirely acceptable.

C. Column Size

2.06 The maximum column size (cross-sectional area) that can be used in the standard floor plan is 2 feet 2 inches (parallel to the frame lineups) by 2 feet 4 inches. This size allows at least a 3-inch clearance between the column and adjacent

frames, and a minimum 1-foot 8-inch wiring aisle between the columns and cross-aisle frames. The 1-foot 8-inch aisle width allows sufficient access for most frames and rolling test equipment. If larger columns are necessary in the lower stories of a very tall building, a few frames must be omitted from the cross-aisle lineup.

D. Cable Holes

2.07 A cable hole pattern suitable for use with flatslab floor construction (see Section 760-200-100) is recommended as standard. The cable hole size and spacing (see Fig. 2) will provide clearance between vertical cable runs and either 18-inch wide cross-aisle troughs located on 5-foot centers (see Fig. 3), or 12-inch wide cross-aisle cable troughs located at 1-foot 1-inch increments along standard ESS lineups (see Specification J1A054). See Section 760-200-032 for information on standard cable holes.

3. CENTRAL OFFICE DESCRIPTION

3.01 The spatial features of a functional and efficient central office are presented in the following material. This description of the central office is divided into four parts corresponding to the main subdivisions of the total equipment area: the equipment frame, power, distributing frame, and cable entrance areas.

A. Equipment Frame Area

3.02 Elevation views of the two standard configurations in typical equipment frame areas are shown in Fig. 4. One configuration features a Conventional Cooling System (CCS), and the other, the Modular Cooling System (MCS). The CCS is an all-air system which employs central fan rooms, overhead ducts, and diffusers for air distribution. The MCS incorporates a raised floor, water-cooled fan-coil units (process coolers) located near the equipment frames, a suspended ceiling or ductwork for local distribution of cooling air, an underfloor chilled-water distribution system, some telephone cable and electrical conduit, condensate and humidifier piping, smoke detectors, and an air-return system for the process coolers. The MCS is intended for use in areas where the equipment heat dissipation over large areas averages from 25 watts/square foot to 100 watts/square foot. See Section 760-230-100.




Fig. 3—Cable Pathways Plan for 12-Inch Deep Frame Areas




Fig. 4—Typical Equipment Frame Areas

3.04 The floor is designed for a basic live load of 150 psf. In general, a uniform floor load allowance of 115 psf is allocated to equipment, 25 psf to cable distribution systems, and 10 psf to transient loads such as personnel, portable or rolling test equipment, and equipment being transported. These maximum uniform floor load allocations are related to the total of the actual weights of various equipment distributed nonuniformly across a floor area, divided by that area. The process-cooler and raised floor load is included with the equipment frame load.

3.05 All equipment frames are 7 feet high and are supported by the floor or supportwork. They may be connected at the top to adjacent frames, but cross-aisle support at the top or connection to the ceiling is not required unless specified for earthquake bracing. See Section 760-200-041 for equipment support standards.

3.06 The overhead interframe cable and associated cable racks, which together are called cable distribution systems (CDSs), are divided into two main categories: system CDSs and via CDSs.

3.07 System CDSs feature racks designed for and dedicated to a single equipment system such as No. 4 ESS. All cabling interconnecting frames within this equipment system are included within these racks. All other cabling which originates

outside a particular equipment system and passes over or terminates in it is called via cabling and is carried in the via CDS. Via racks include all vertical cable runs in multistory buildings.

3.08 The 7- to 10-foot space is allocated between system and via cable racks, lights and passages for cooling air, and installer access according to the plan shown in Fig. 3. This allocation, known as the Cable Pathways Plan, coordinates these elements and eliminates possible conflicts throughout the life of the equipment-building system. Cable racks and lights are located as required in the pathways (see Fig. 3) and according to the following rules:

- (1) System cable racks running parallel to equipment lineups are located between 7 to 8 feet above the floor and directly over the lineups. A minimum spacing of 2 feet in the maintenance aisle and 1 foot 4 inches in the wiring aisles is maintained between system lineup racks.
- (2) System cable racks running transverse (cross aisle) to equipment lineups are located within the cross-aisle cable pathways situated 8 to 9 feet above the floor on 5-foot centers across the equipment area, (see Fig. 3) to avoid cable holes and columns, to provide for installer access to cable racks, and to maintain unobstructed

"windows" for cooling air. The maximum width of these cable racks is 18 inches. No more than 75 percent of the total cross-aisle pathways capacity per building is used for cross-aisle system cable racks.

(3) Via cable racks running parallel to equipment lineups are located within the cable pathways situated 9 to 10 feet above the floor and directly over the lineups. These racks should be 1 foot wide or less and located over at most three equipment lineups per building bay.

(4) Via cable racks running perpendicular (cross aisle) to equipment lineups shall be located within the cross-aisle cable pathways situated 8 to 9 feet above the floor on 5-foot centers across the equipment area. These via cable racks share the cross-aisle pathways with the system cable racks. A minimum of 25 percent of the cross-aisle pathway capacity shall be reserved for via cable racks.

(5) Lights shall be located over maintenance aisles between 7 feet 3 inches and 8 feet above the floor and on the same 5-foot centers as the cross-aisle cable pathways. This places them directly below the cross-aisle pathways and thus below any cable racks.

(6) With a CCS, the air diffusers are located at the 10-foot level directly over the "windows" between cross-aisle cable pathways to provide an unobstructed flow of cooling air into the equipment aisles. The air diffuser support can be provided by the building engineer or by Western Electric. In the latter case, a superstructure is suspended from the ceiling inserts (see Fig. 3) to support air diffusers, and via cable racks, if necessary.

3.09 See Section 801-801-182 for further information on NEBS Cable Distribution and Systems Assembly.

3.10 The floor load from overhead cable distribution systems and lights does not exceed 25 psf. This is allocated 20 psf for system CDSs and 5 psf for via CDSs. In nonearthquake areas, system and via CDSs and lights are generally supported by the frames below. Over partially equipped lineups they shall be supported by floor mounted stanchions. Over unequipped areas, via CDSs shall be supported by stanchions or from the ceiling. In

earthquake areas, all via cabling shall be ceiling-supported and braced. All system CDSs in earthquake areas are frame-supported, as in non-earthquake areas.

3.11 The principal floor plan for the equipment frame area is shown in Fig. 2. The majority of equipment in the area is designed to be maintained and operated in this or similar floor layouts. If an MCS is used in the area, process coolers are to be located in the column rows over an unused cable hole. If an MCS is not used, that space is available for other telephone equipment.

3.12 Nonstandard equipment or exceptional operating requirements will occasionally dictate exceptional floor plans in the equipment frame area. Such plans should be avoided because they tend to complicate and disrupt central office planning and design and often result in wasteful use of space and services. Therefore, most equipment frames will be located in such lineups as shown in Fig. 2.

3.13 No. 1 and No. 2 ESS Equipment:

Lineup cable racks and cross-aisle cable troughs, per Specification J1A054, are used for the system cabling in No. 1 and No. 2 ESS offices (see Fig. 5). Via cables are supported from the superstructure over the same lineups in non-earthquake areas, eliminating the need for ceiling support in this area. Over areas lacking frame lineups, the via cabling may be supported by stanchions or from the ceiling. In earthquake areas via cabling is ceiling-supported and braced. Via cabling should be planned in conformance with the Cable Pathways Plan.

3.14 No. 4 ESS, Digital and VF Terminal Equipment:

The J90606 Cableway System distributes the system cabling for the No. 4 ESS voice frequency terminal and for digital transmission (T-carrier) systems in No. 2 ESS offices. The system cable racks occupy the 7-foot to 8-foot 3-5/8 inch levels (see Fig. 6). The lighting and via cable support are similar to that found over the No. 1 ESS area. The cableway conforms to all requirements of the Cable Pathways Plan.

3.15 Broadband Carrier Equipment:

The J90606 Broadband Cableway meets all the requirements for LMX-3, MGT, MMGT, and L5 carrier equipment with associated distributing frames in NEBS offices. The system cable racks are




Fig. 5—Heights of Cable Racks and Frame-Supported Lights for No. 1 and No. 2 ESS




Fig. 6—Heights of Cableway System and Lights for No. 4 ESS, VF Terminal, and Digital Carrier Equipment

located in the 7- to 9-foot levels (see Fig. 7) and make provision for via cable racks and lights in conformance to the Cable Pathways Plan with the 10-foot clear ceiling height.

3.16 Digital Carrier Equipment: The J90606

Digital Cableway System is used to distribute the system and via cabling for digital transmission (T-carrier) systems. The only exception is that the No. 4 ESS Cableway System should be employed over the digital equipment frames located in No. 2 ESS offices. The system lineup racks are located between the 7- to 8-foot levels, system and via cross-aisle racks are placed in the 8- to 9-foot space, and lineup via racks are installed in the 9- to 10-foot region (see Fig. 8). The lineup via racks and cross-aisle racks are identical to those used in

broadband carrier offices. The Digital Cableway System and its associated lighting system conform with the Cable Pathways Plan.

B. Power Areas

3.17 Telephone Power: A typical telephone

power equipment area is shown in Fig. 9. This area is primarily for dc electrical power equipment that is not installed in lineups with communications equipment. However, new cable-type power plants are often placed next to or between associated communication systems. Power equipment located in these areas has a maximum height requirement of 10 feet, which includes the necessary overhead clearance for installation, operation, or maintenance of the equipment. As




Fig. 7—Typical Cableway Four-Compartment Over Equipment Frames




Fig. 8—Typical Cableway Arrangement Over Digital Equipment Frames

in the communication equipment areas, the power equipment may be on the structural floor or on a raised deck that is part of the MCS. In either case, the vertical space allotment is 10 feet. This maximum height includes all equipment, cable and supports, bus bars, lighting, and room for top access. When the power plant is located on the same floor with the communication equipment, provision for via cabling should be included in the space allotment of 10 feet. Floor Plan Data Sheets show equipment layouts that result in average live floor loads of 140 psf or less. This does not preclude the provision of dedicated areas with higher floor loads, such as large engine generators and battery plants. Engineering information is available which shows mounting methods to achieve floor support of all telephone power equipment, including cables, bus bars, battery stands, and lighting for use with the NEBS. See Section 760-240-100.

3.18 Building Power: A typical building power equipment area is shown in Fig. 10. This type of equipment area is primarily devoted to the main building ac switchgear or to substations for distributing ac power within the building. The equipment located in this area has normally been engineered and installed by other than Bell System personnel.

3.19 Main ac switchgear and transformer equipment is likely to be located on the base slab where high average floor loads impose no economic penalty. However, substations or ac load centers located on upper building floors can be arranged to meet the 140-psf average live load and 10-foot clear ceiling height criteria. The engineer responsible for the design of this system can make provisions above the floor switchgear for ac busduct and cable. See Section 760-240-110.




Fig. 9—Typical Telephone Power Equipment Area. If the MCS is used, equipment would be installed in a 10-foot-high space atop the high supportwork and deck and below the suspended ceiling.




Fig. 10—Typical Building Power Equipment Area

3.20 Engine-Alternator Plant: Engine plants of less than 100 kW require no special provisions with respect to 140-psf floor loading and 10-foot clear ceiling height criteria. However, the megawatt-size engine-alternators (100 kW or

greater) require special planning. A typical large capacity engine plant area is shown in Fig. 11. The megawatt engine plant is shown without a dropped ceiling air-conditioning system for installation under a 12-foot 6-inch structural ceiling height. In

these plants, most air and exhaust ducts, electrical busduct, and cable are floor supported. See Section 760-240-120.

C. Distributing Frame Area

3.21 A typical modular distributing frame (MDF) area is shown in Fig. 12. This illustrates connecting frames not usually included in equipment frame lineups. The MDFs are the most common example of such frames. These frames, together with all cable racks, are limited to 9 feet in height. As with equipment frames and power equipment, the distributing frames may be on the floor or on the raised deck of an MCS; in which case, the 10-foot vertical space allotment is simply raised 18 inches. The overhead cable and associated racks rest on the frames below. The floor load allocation is 140 psf for all distributing frame equipment in this area, including cable.

3.22 Figure 12 illustrates a cable rack layout for double lineups of modular MDF and protector frames. This arrangement provides sufficient capacity for the recommended cable spreads between MDF and protector frame, between MDF and line equipment, and between tie pairs.

3.23 This plan is acceptable for the complete range of building sizes; however, some

problems may arise for some very large wire centers with more than 280,000 outside plant pair terminations. In such buildings, multilevel cable racks may be required to provide an orderly cabling arrangement because of the very large cross section of cable installed over the MDF. The CCS standards provide 2 feet 6 inches of space for equipment cooling air distribution in addition to the 10 feet of space for equipment and cabling. In this area of low heat load, space allocated to cooling air distribution may be reallocated to cabling; however, special engineering will be required, and special effort will be necessary to coordinate plans for cabling and cooling air distribution.

D. Cable Entrance Area

3.24 The Cable Entrance Facility (CEF) (formerly called cable vault) and associated equipment is now subject to the same standards as other central office space. A vertical clearance of 10 feet is allocated to equipment, and the maximum floor load is 140 psf for all equipment and cable. Environmental features and requirements, such as temperature, illumination, air quality, etc, are maintained as in other equipment areas, except that no provisions as made for the MCS. See Section 760-200-030.




Fig. 11—Typical Megawatt Engine Plant Equipment Area




Fig. 12—Typical Modular Distributing Frame Area. If the MCS is used, equipment would be installed in a 10-foot-high space atop the 18-inch-high supportwork and deck and below the suspended ceiling.

E. Equipment Hoisting Area

3.25 Equipment frames that are to be installed in a central office building are to be brought, in their horizontal crated position, to the equipment hoisting area. Equipment hoisting areas are located adjacent to the building access opening on each floor. The area is used to rotate equipment frames to an upright position using hoists or an A-type gantry crane supplied by Western Electric. Once frames have been rotated upright, they are transported by dolly trucks to their installation locations in lineups.

3.26 The hoisting area should be at least 12 by 20 feet in plan. In central offices with the CCS, this is accomplished by selecting areas not limited by overhead air ducts. In central offices equipped with the MCS, the clear space is obtained by the removal of modular ceiling panels (temporarily or permanently), which will provide 11 feet above a raised floor surface or 12 feet 6 inches above the permanent concrete floor.

3.27 More vertical space than is available with a gantry hoist exists where hoists are suspended from ceiling anchors. This is because such hoist

units are located above the room's 10-foot clear area.

4. REFERENCES

1. ANSI A62.1 and ANSI A62.7—Coordinated Dimensions of Building Components and Materials
2. 760-200-030—Cable Entrance Facility (CEF)
3. 760-200-032—Cable Openings—Design Standards
4. 760-200-041—Equipment Support
5. 760-200-100—Structural Floors
6. 760-200-152—Column Spacing in Equipment Rooms
7. 760-230-100—Equipment Cooling
8. 760-240-100—DC Power Plants
9. 760-240-110—Building Power
10. 760-240-120—AC Emergency Power
11. 760-550-300—Modular Cooling System Planning and Engineering Guidelines
12. 800-610-164 (and PUB 51001)—New Equipment Building System (NEBS)
13. 801-006-158 (J90606)—Cableway Systems for Electronic Offices Using 7-Foot Frameworks Equipment Design Requirements—Common Systems
14. 801-801-155 (J1A054)—Lineup Cable Racks and Cross-Aisle Cable Troughs for 7-Foot Framework
15. 801-801-182—NEBS Cable Distribution and Systems Assembly
16. 802-015-160 (J85515)—Central Office Lighting—Fluorescent Type
17. Modular Cooling System—Planning and Engineering Guidelines

SECTION 760-100-030

5. SUMMARY OF NEBS STANDARDS

- 5.01** Vertical space assignment of the floor-to-ceiling height and load assignment of the floor live load capacity are shown in Table A.
- 5.02** The building bay size is 20 feet square measured center-to-center of columns and center-to-surface of peripheral walls. See Section 760-200-152.
- 5.03** Cable holes are located, three per building bay, in column rows parallel to equipment lineups in equipment areas (see Fig. 2), and designed as recommended in Section 760-200-032.
- 5.04** All system and via cable distribution systems shall be located in conformance to the Cable Pathways Plan (see Fig. 3) and discussed in Section 801-801-182. The frame and aisle lighting, ceiling inserts, and air diffusers, if required, are integrated into the plan as shown.

TABLE A

EQUIPMENT	VERTICAL SPACE	FLOOR LOAD (psf)
Equipment Frame Area		
Frames	Floor to 7 ft*	115*
Cable distribution system and installation clearances (includes allocation of 5 psf for via cable at 9 to 10 feet)	7 to 10 ft	25
Power Area		
All equipment, cable, and installation clearances	Floor to 10 ft*	140
Distributing Frame Area		
All equipment, cable (including via cable), and installation clearances	Floor to 10 ft*	140
Cable Entrance Area		
All equipment, cable, and installation clearances	Floor to 10 ft	140
Conventional Cooling System (CCS)		
Overhead ducts and diffusers	10 to 12-1/2 ft	†
Modular Cooling System (MCS)		
Raised deck and supportwork	Floor to 1-1/2 ft	10
Supply, return, and drain piping	Floor to 1-1/2 ft	†
Process coolers	1-1/2 to 11-1/2 ft	115
Suspended ceiling (air plenum and lights)	11-1/2 to 12-1/2 ft	†
Transient loads	—	10

* The following apply in equipment areas where the MCS and/or raised deck is used:

- Vertical space dimensions from the floor are increased 18 inches, since equipment is placed on top of an 18-inch high raised deck.
- Floor load allocations include the weight of process coolers, raised deck, and supportwork.

† The weights of these items are considered "dead load."