

STORAGE AND HANDLING OF FLAMMABLE LIQUIDS

1. GENERAL

1.001 This addendum supplements Section 770-300-152, Issue 1.

1. GENERAL

Change paragraph 1.05 to read:

1.05 Storage cabinets for flammable liquids should be constructed as covered in Chapter IV, Paragraph 42 of the "Flammable and Combustible Liquids Code." Cabinets that meet this requirement are available commercially.

3. GENERAL RULES

Add paragraph 3.06 to read:

3.06 Storage of Class II and Class III liquids in aggregate amounts exceeding 10 gallons in one storage area should be stored in Approved Cabinets. Lesser amounts should be sealed tight in original containers or "Safety Cans" and stored in metal lockers.

7. PAINTS, ENAMELS, VARNISH, SHELLAC AND ASSOCIATED PRODUCTS

Change paragraph 7.01 to read:

7.01 The storage of paints and associated products in Telephone Equipment Buildings should be kept to minimum quantities required for routine maintenance. Small quantities used for touch up should be kept in original container and stored in metal lockers.