

## CABLING DIAGRAMS FOR SCHEMATIC CIRCUIT DRAWINGS GENERAL EQUIPMENT REQUIREMENTS

### 1. GENERAL

**1.001** This addendum supplements Section 800-610-153, Issue 7.

**1.002** This addendum is issued to add terminal assignments where two or more circuits are assigned to a row of terminals.

### 2. DETAILS OF CABLING, TERMINAL ASSIGNMENT, AND CROSS-CONNECTING INFORMATION

The following changes apply to Part 2 of the section:

(a) 2.18—revised.

*Change 2.18 to Read:*

**2.18** *On 150-, 178-, 268-, 183-, and similar-type terminal strips,* in assigning terminals in a row of terminals which are perpendicular to the fanning strip, the "tip" lead should be shown connected to the terminal farthest from the fanning strip; "ring" to the next farthest terminal from the fanning strip; "sleeve" next; and so on in toward the fanning strip. Where two or more circuits are assigned to a row of terminals, the terminals for the lowest numbered circuit shall be away from the base of the terminal strip and the terminals for the highest numbered circuit shall be nearest the base of the terminal strip, as shown in Fig. 6 and 16.