

METAL WORK
GENERAL EQUIPMENT REQUIREMENTS

1. GENERAL

1.001 This addendum supplements Section 800-611-151, Issue 3.

1.002 This addendum is issued to

- (a) Change the wording in paragraph 4.03.

2. CHANGES TO SECTION

2.001 On page 12, change the first sentence of paragraph 4.03 to read as follows: Individual frames, such as shop-assembled and shop-equipped bays and frames, relay racks, fuse bays, etc., should conform to the specified overall dimensions to within $\pm 1/8$ inch in height and $\pm 1/16$ inch in width.

NOTICE

Not for use or disclosure outside the
Bell System except under written agreement