

AT&T ENGINEERING REQUIREMENT CHANGE NOTIFICATION - ATT-TP-76400-003

TO: ALL AT&T ENGINEERING SUPPLIERS

Date: 04-23-04

EFFECTIVE DATE: 5 days from posted date or as per Supplier's Contract

Submitter's Name: TP Team

TP: TP76400 **Subject:** Marking "Fiber Only" Requirements **Action:** Add **Modification:** **Delete:**

Section: 8 **Section Title:** CABLE RACK, AUXILIARY FRAMING AND LIGHTING SYSTEMS

Subsection: 4 **Section Title:** CABLE DISTRIBUTION SYSTEMS

Subsection: 4.4 **Subsection Title:** Fiber Protection System (FPS)

Prior to Change:

4.4.5 An approved Fiber Protection System (FPS) shall be used for fiber optic patch cords between the FDF and the equipment/network element. The FPS shall be dedicated for "fiber only" and clearly marked as such. The Fiber Protection System shall be provisioned along the entire length of the FDF and extended from the FDF to the associated network element.

Post Change:

4.4.5 An approved Fiber Protection System (FPS) shall be used for fiber optic patch cords between the FDF and the equipment/network element. The Fiber Protection System shall be provisioned along the entire length of the FDF and extended from the FDF to the associated network element.

Questions relative to this ERCN should be addressed to Laurie Gustin at 310-640-4220

Laurie Gustin

Project Manager Area Manager, NP&E

Enterprise Technology Support

Laurie.gustin@att.com

Access the TP's on the Extranet Site <https://ebiznet.sbc.com/sbcnebs>

Concurred

Senior Engineering Manager-Network Quality, West
(Laurie Page)

Date: 04-23-07

Senior Engineering Manager-Network Quality, Southwest
(Crissy Holmes)

Date: 04-23-07

Senior Engineering Manager-Network Quality, Midwest
(Charles Stahulak)

Date: 04-23-07

Area Manager Common Systems **(Subject Matter)**
(SME)

Date: 04-23-07

Release Approved

Area Manager Enterprise Technology Support
(Mike Burghardt)

Date: 04-23-07