

5ESS® SWITCHING EQUIPMENT
6 FAN UNIT
CIRCUIT

CHANGES

B. Changes in Apparatus

B.1 The 6 inch fan used in this fan unit will be replaced by an equivalent fan that is thermostatically controlled by a thermistor mounted on the fan. For field replacements, fans will be ordered by the customer and sent to the field for changeout in the existing fan units.

B.2 This change is being applied to reduce acoustic noise generated by the fan units.

B.3

SUPERSEDED

SUPERSEDED BY

A through G FANS APP FIG. 1
KS22501L3
Z OPTION

A through G FANS APP FIG. 1
KS23912L1
Y OPTION

AT&T BELL LABORATORIES

DEPT 55531-JFW-MWR

5

5ESS™ SWITCHING EQUIPMENT
6 FAN UNIT
CIRCUIT

CHANGES

D. Description of Changes

D.1 Updated the documentation to reflect the use of the 6-fan unit in the SMC cabinet.

F. Changes in CD Sections

F.1 Part of Section I, Paragraph 2.01 should be modified as follows:

Circuitry to detect and report a fan failure to the Input/Output Processor (IOP) or to the Switching Module Processor (SMP) is provided.

F.2 Add the following to Section III, Paragraph 2:

- 2.03 Switching Module Processor Unit, SD-5D129-01
- 2.04 Module Controller and Time Slot Interchange Unit, SD-5D094-01
- 2.05 Switching Module Control Cabinet, SD-5D118-03

AT&T NETWORK SYSTEMS

DEPT 11NW527280-GM-EBH

NOTICE

This document is either
AT&T - Proprietary, or WESTERN
ELECTRIC - Proprietary

Pursuant to Judge Greene's Order of August 5, 1983 beginning on January 1, 1984, AT&T will cease to use "Bell" and the Bell symbol, with the exceptions as set forth in that Order. Pursuant thereto, any reference to "BELL" and/or the BELL symbol in this document is hereby deleted and "terminated".

Printed in U.S.A.

Page 1
1 Page

CIRCUIT DESCRIPTION

CD-5D081-01
ISSUE 1
APPENDIX 1D
DWG ISSUE 2D
DISTN CODE 7T13

5ESS™ SWITCHING EQUIPMENT

6 FAN UNIT
CIRCUIT

CHANGES

D. Description of Changes

D.1 Updated documentation, including the following:

- (a) On FS 1 and App Fig. 1, changed fan alarm circuit from "circuit pack 233A" to "circuit module CM233A."
- (b) Added battery information to Circuit Note 101.
- (c) Added Circuit Note 105.

AT&T BELL LABORATORIES

DEPT 55613-GM-JCB

NOTICE

This document is either
AT&T - Proprietary, or WESTERN
ELECTRIC - Proprietary

Pursuant to Judge Greene's Order of August 5, 1983,
beginning on January 1, 1984, AT&T will cease to use
"Bell" and the Bell symbol, with the exceptions as set
forth in that Order. Pursuant thereto, any reference to
"BELL" and/or the BELL symbol in this document is here-
by deleted and expunged.

Printed in U.S.A.

Page 1
1 Page

5ESS™ SWITCHING EQUIPMENT
6 FAN UNIT
CIRCUIT

SECTION I - GENERAL DESCRIPTION

1. PURPOSE OF CIRCUIT

1.01 The six fan unit is a part of the communications module model 2 (CM2) for the 5ESS TM switching system. The minimum configuration for a simplex CM2 includes one six-fan unit. The six-fan unit provides air flow for maintaining correct operating temperatures.

2. GENERAL DESCRIPTION OF OPERATION

2.01 Six separate fans are used in the six-fan unit. Only five are required to provide sufficient air flow, thereby ensuring correct operating temperature can be maintained in the event of a single fan failure.

2.02 Circuitry to detect and report a fan failure to the input/output processors (IOP) is provided. This is done via a scan point from the unit. A fan failure alarm can be retired manually, or under software control using a distribute point to the fan unit.

SECTION II - DETAILED DESCRIPTION

1.01 The 233A fan alarm circuit pack is used for detecting and reporting fan failures in the six-fan unit. This requires detecting a fan failure and activating the corresponding visual displays for the faulted fan in both the unit and the cabinet. A scan point is also activated to be used for software detection of the "fan failure."

NOTICE

This document is either
AT&T - Proprietary, or WESTERN
ELECTRIC - Proprietary

Pursuant to Judge Greene's Order of August 5, 1983, beginning on January 1, 1984, AT&T will cease to use "Bell" and the Bell symbol, with the exceptions as set forth in that Order. Pursuant thereto, any reference to "BELL" and/or the BELL symbol in this document is hereby deleted and expunged.

1.02 The 233A provides a reset capability for retiring a fan failure alarm. This is accomplished by momentarily removing power to the alarm detection circuitry, integral to each fan, and can be activated by a momentary switch or software controllable distribute point. Each fan of the fan unit is powered by a separate -48V feeder, and the alarm circuit board (233A) obtains power (-48V) from two of those six fans.

1.03 The functions of the six-fan unit are:

- (a) Detect the loss of any one of the six fans through the "fan failure" scan point. The appropriate LED for the failure fan on the fan unit must also be lit as well as the "fan failure" LEDs at the top of the cabinet where the faulted fan is located. No other LEDs on the six-fan unit can have their LEDs lit.
- (b) The "clear fan failure" distribute point is used to clear a "fan failure" alarm in software. If the faulty condition no longer exists, the LEDs on the six-fan unit and the cabinet cannot be lit.
- (c) A reset button on the back of the six-fan unit is provided to clear a "fan failure" alarm manually. If the faulty condition no longer exists, the LEDs on the six-fan fan unit and the cabinet must extinguish themselves.

2. CAD 01:

2.01 CAD 01 contains the following information:

- (a) The input (-48V, 48RTN) for the 233A circuit pack are provided by terminal block 0 (TB0).
- (b) The input (+5V, GRD) for the fans in the unit are provided by the 233A circuit pack.
- (c) Lists the two leads for the reset button (SW1, SW2).

3. CAD 02:

3.01 CAD 02 lists the scan point (SCANR, 3BSCAN0) and the reset distribute point (RSTR, 3BRST1) of the 233A circuit pack. The scan point and distribute point go to IO/P0 or a preceding six-fan unit.

4. CAD: 03:

4.01 CAD 03 lists the scan point (SCANR, 3BSCAN0) and the reset distribute point (3BRST1, RSTR) of the 233A circuit pack. This scan point and distribute point go to IO/P1.

5. CAD 04:

5.01 CAD 04 lists the scan point (SCANR, 3BSCAN0) and the reset distribute point (RSTFANS, RSTFAN) of the 233A circuit pack. This scan point and distribute point go to a succeeding fan unit.

6. CAD 05:

6.01 CAD 05 lists all the leads for the alarm LEDs (A,B,C,E,F,G) which connect to the appropriate LEDs on the six-fan unit.

7. CAD 06:

7.01 CAD 06 lists all the leads for the cabinet alarm LEDs connected at the appropriate LEDs on the top of the cabinet.

8. CAD 07:

8.01 CAD 07 lists scan point for potential future use.

9. CAD 08:

9.01 CAD 08 listed the alarm signals from the fans. These leads are used by the 233A circuit pack to detect a faulty fan.

10. CAD 09:

10.01 The CAD contains information on the two terminal blocks 0 and 1 (TB0, TB1). These TBs are used to interface between the fuse/filter panel, the LEDs and the fan unit. CAD 09 listed the following information:

- (a) The power input (-48V, 48RTN) from the fuse/filter panel which are used to run the fans.
- (b) The power input (+5V, GRD) of the 233A circuit pack which are provided to the fans.
- (c) The alarm leads of the fans which are used to indicate an alarm to the 233A circuit pack when a faulty fan is detected.

SECTION III - REFERENCE DATA

1. WORKING LIMITS

1.01 Voltages:

- (a) -42.75 to -52.5 volts (nominal -48 volts).

1.02 Ambient Temperature

- (a) 0 to 70 degrees centigrade (at circuit pack).
- (b) 0 to 50 degrees centigrade (office aisle ambient).

2. CONNECTING CIRCUITS

2.01 Fuse/filter panel: SD-5D146-01

2.02 Input/output processor:
SD-5D053-01

AT&T BELL LABORATORIES

DEPT 55614-JTC-CEJ