



TABLE A-FEATURES

EQUIPMENT		EQUIPMENT OR CIRCUIT DATA							SD EQUIVALENT		
DESCRIPTION	REF NOTE	RAT-ING	LIST OR GROUP	QTY	EQUIPMENT OR CIRCUIT	L/G OR FIG	WRG	APP	SCHEMATIC	FIG	OPT
EQUIPMENT REQUIRED FOR 1 CROSS AISLE CABLE TROUGH OVER A EQUIPMENT AISLE 20 TO 26 INCHES IN WIDTH; ONE T&R CABLE TROUGH OVER A WIRING AISLE 20 TO 24 INCHES IN WIDTH; ONE NCT CABLE TROUGH OVER A WIRING AISLE 20 TO 32 INCHES IN WIDTH. DA EFF:05/30/97 FE:ED5D510-71,1		DA	1								
EQUIPMENT REQUIRED FOR 1 CROSS AISLE CABLE TROUGH OVER A EQUIPMENT AISLE 27 TO 44 INCHES IN WIDTH; ONE T&R CABLE TROUGH OVER A WIRING AISLE 25 TO 40 INCHES IN WIDTH; ONE NCT CABLE TROUGH OVER A WIRING AISLE 33 TO 46 INCHES IN WIDTH. DA EFF:01/12/01 FE:ED5D510-71,2		DA	2								
EQUIPMENT REQUIRED FOR ONE NCT ADAPTER USED AT EA. CROSS AISLE TROUGH TERMINATING AT THE NCT SECTION OF THE LINEUP CABLE RACK. DA EFF:05/30/97 FE:ED5D510-71,15		DA	3								
EQUIPMENT REQUIRED FOR ONE NCT BRDGE ASSMBLY USED OVER LINEUP CABLE RACK FROM EACH NCT CROSS AISLE TROUGH TO NCT SECTION AT REAR OF CABLE RACK. DA EFF:01/12/01 FE/RA:NONE		DA	4								
EQUIPMENT REQUIRED IN ADDITION TO GROUP 1,2 & 9 TO SUPPORT A CROSS AISLE CABLE TROUGH OVER A EQUIPMENT AISLE. DA EFF:01/12/01 FE:ED5D510-71,5		DA	5								
EQUIPMENT REQUIRED IN ADDITION TO GROUP 1,2 & 9 TO SUPPORT A CROSS AISLE CABLE TROUGH OVER A WIRING AISLE. DA EFF:01/12/01 FE:ED5D510-71,6		DA	6								
EQUIPMENT REQUIRED FOR A VIA SYSTEM AT HGT OF 8FT-0IN HIGH. DA EFF:01/12/01 FE:ED5D510-71,7		DA	7								
EQUIPMENT REQUIRED FOR A VIA SYSTEM AT A HGT OF 9FT-0IN HIGH. DA EFF:01/12/01 FE:ED5D510-71,8		DA	8								
EQPT REQUIRED FOR ONE CROSS AISLE CABLE TROUGH OVER A EQUIPMENT AISLE 45 TO 60 INCHES IN WIDTH; ONE T&R CABLE TROUGH OVER A WIRING AISLE 41 TO 60 INCHES IN WIDTH; ONE NCT CABLE TROUGH OVER A WIRING AISLE 47 TO 60 INCHES IN WIDTH. DA EFF:03/01/97 FE:ED5D510-71,9		DA	9								
END OF TABLE-A											

ED5D510-70

COPYRIGHT © 2001 LUCENT TECHNOLOGIES  
ALL RIGHTS RESERVED

BT99

5ESS SWITCHING EQUIPMENT  
SPECIFICATION FOR  
CROSS AISLE CABLE TROUGHS  
ASSEMBLY AND STOCKLIST

DWG SIZE C2 ISSUE 12

LUCENT TECHNOLOGIES INC ED5D510-70

SHEET A2 OF 3

STOCKLIST									
ITEM NBR	LIST GROUP CODE	QTY PER CODE	PRODUCT IDENTIFIER	CODE	DESCRIPTION	REFERENCE POSITION	NOTE		
							SYM	NBR	
1010	1	1	843071341		TROUGH 6 IN X 6 IN (OUTER 20 IN) TIP & RING				
1020	1	1	843071366		TROUGH 6 IN X 6 IN (INNER 20 IN) TIP & RING		*		
1030	2	1	843071358		TROUGH 6 IN X 6 IN (OUTER 30 IN) TIP & RING				
1040	2	1	843071374		TROUGH 6 IN X 6 IN (INNER 30 IN) TIP & RING		*		
1050	3	1	843071390		ADAPTER		S		
1060	4	1	843071408		BRIDGE CROSS AISLE				
1080	1,2,9	2	803690171	P-369017	WASHER, INTERNAL TOOTH LOCK		*		
1090	1,2,9	2	814477410	P-44G741	SCREW, BUTTON HEAD SOCKET CAP .375-16		*		
1110	4	1	803690171	P-369017	WASHER, INTERNAL TOOTH LOCK		*		
1120	4	1	814477410	P-44G741	SCREW, BUTTON HEAD SOCKET CAP .375-16		*		
1130	5	2	843071697		BRACKET				
1140	6	2	843071689		BRACKET				
1150	5,6	2	801472853	P-147285	SCREW, HEXAGON HEAD CAP .375-16 X 1-1/2		*		
1160	7	1	843071416		ASSEMBLY, SUPPORT LOWER VERTICAL		S		
1170	7	1	843071424		ASSEMBLY, SUPPORT UPPER VERTICAL		S		
1180	8	1	843071416		ASSEMBLY, SUPPORT LOWER VERTICAL		S		
1190	8	1	843071432		ASSEMBLY, SUPPORT UPPER VERTICAL		S		
1210	7,8	2	801472853	P-147285	SCREW, HEXAGON HEAD CAP .375-16 X 1-1/2		*		
1230	7,8	2	801829599	P-182959	WASHER, SPRING LOCK (.375) 289A FINISH		*		
1240	9	1	843071705		TROUGH 6 IN X 6 IN (OUTER 40 IN) TIP & RING				
1250	9	1	843071713		TROUGH 6 IN X 6 IN (INNER 40 IN) TIP & RING		*		
1260	5,6	2	801829599	P-182959	WASHER, SPRING LOCK (.375) 289A FINISH		*		
1270	7,8	2	804055424	P-405542	BOLT, CARRIAGE		*		
1280	7,8	4	802584490	P-258449	CLIP		*		
1290	7,8	2	814478236	P-44G823	INSULATOR		*		
1310	7,8	2	814570875	P-45G087	BUSHING, INSULATING		*		
1320	7,8	2	803865781	P-386578	WASHER		*		
1330	7,8	2	841064777		NUT, HEXAGONAL 3/8-16, STEEL 289A FINISH		*		
1340	7	1	846571867		BRACKET, ASSEMBLY				
1350	8	1	845620210		BRACKET				
***** END OF STOCKLIST *****									

S  
H  
O  
P  
L  
I  
S  
T

MANUFACTURING NOTES

1. X PARTS REQUIRED FOR INSTALLATION.

X/ PARTS REQUIRED FOR MANUFACTURE WHEN EQUIPMENT IS SHOP MOUNTED OR BY THE INSTALLER WHEN THE EQUIPMENT IS TO BE FIELD MOUNTED.

\* PARTS THAT ARE TO BE SHIPPED ATTACHED TO OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED ASSEMBLED ITEM.

\*/ PARTS (A) REQUIRED FOR MANUFACTURE WHEN EQUIPMENT INVOLVED IS SHOP MOUNTED OR (B) TO BE SHIPPED ATTACHED TO, OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED ASSEMBLED ITEM WHEN FIELD MOUNTED.

( ) INDICATES DESIGNATIONS TO BE STAMPED IN ACCORDANCE WITH JOB INFORMATION.

{ } INDICATES DESIGNATIONS SHOWN FOR INFORMATION ONLY AND ARE NOT TO BE STAMPED.

< > INDICATES DESIGNATIONS AND/OR INFORMATION PROVIDED IN ACCORDANCE WITH OTHER INFORMATION.

"W" PARTS ASSEMBLED AT THE SAME TIME THE EQUIPMENT IS MOUNTED.

"W\*" PARTS TO BE (A) SHOP ASSEMBLED, BUT WHICH CANNOT BE ASSEMBLED UNTIL THE ASSOCIATED EQUIPMENT IS BEING MOUNTED, OR (B) SHIPPED ATTACHED TO, OR ENCLOSED IN THE SAME CONTAINER WITH THE ASSOCIATED EQUIPMENT WHEN FIELD MOUNTED.

"S" PARTS NOT ASSEMBLED, SHIPPED SEPARATELY.

A/R AS REQUIRED.

"B" PARTIAL ASSEMBLIES ON OTHER DRAWINGS WITH STOCKLISTS.

12. PARTS NOT MARKED CONSTITUTE THE MAJOR ASSEMBLY AND ARE TO BE ASSEMBLED FOR SHIPMENT.

COPYRIGHT © 2001 LUCENT TECHNOLOGIES ALL RIGHTS RESERVED	
BT99	
5ESS SWITCHING EQUIPMENT SPECIFICATION FOR CROSS AISLE CABLE TROUGHS ASSEMBLY AND STOCKLIST	
DWG SIZE C2	ISSUE 12
LUCENT TECHNOLOGIES INC	ED5D510-70
SHEET D1 OF 3	