

JOINT USE

DECORATIVE STREET LIGHTING ATTACHMENTS

CONTENTS

PAGE

| | |
|---|---|
| 1. GENERAL..... | 1 |
| 2. SPAN WIRES AND MESSENGERS FOR SUPPORTING DECORATIVE GARLANDS AND ELECTRIC LIGHT STREAMERS..... | 2 |
| 3. POWER SERVICE WIRING AND TERMINALS..... | 3 |
| 4. DECORATIVE LIGHT STREAMERS | 3 |

1. GENERAL

1.01 This section describes the considerations involved in the temporary attachment of decorative street lighting circuits and their support wires to solely-owned telephone company poles and to poles jointly-owned by the telephone company. The procedure for handling requests for such attachments is outlined.

1.02 The placing of decorative fixtures, and associated span wires and power service facilities shall conform to the laws of the State of California, Orders of the Public Utilities Commission of said State, rules and regulations of other legally authorized bodies having jurisdiction, the requirements of the Telephone Company (See G10.301-S) and of the Electric Company, insofar as any or all of the foregoing may be applicable.

1.03 Consideration will be given to use of space on poles for decorative street lighting attachments on the following basis:

(a) Requests for attachment privileges received by this company shall be referred to the District Plant Engineer for consideration and approval.

(b) The telephone company's plant engineers shall review the request for making these decorative street lighting attachments with the party or parties making the application or any other interested agencies, and by agreement, shall determine the type of construction to be employed, the location of power wiring, risers, span wire attachments, etc.

(c) The party requesting the attachments will place, or arrange to have placed, such attachments.

(d) All decorative fixtures, and associated span wires, and power service facilities shall be removed after each occasion requiring them.

(e) All maintenance of the decorative lighting attachments shall be performed by the party owning such attachments.

2. SPAN WIRES AND MESSENGERS FOR SUPPORTING DECORATIVE GARLANDS AND ELECTRIC LIGHT STREAMERS

2.01 Span wires or messengers, shall be sectionalized by means of insulators installed not less than 6 feet and not more than 9 feet from each point of attachment. The type of insulator to be used shall be dependent on the highest voltage of the supply conductors at the level on the pole nearest which the span wire or messenger is attached.

2.02 Span wires or messengers attached to poles should preferably be above the communication level with a separation of not less than 12 inches above communication conductors or cables.

2.03 On those poles where it appears necessary to locate the span wires below the telephone wire or cable, the plant engineer shall specify the most desirable level for the attachments. In no case shall the messenger be attached less than 24 inches below telephone cable or allowed to block climbing space.

3. POWER SERVICE WIRING AND TERMINALS

3.01 Power service wiring attachments should preferably be above the communication level with the service terminal located on the pole or on a crossarm. Minimum vertical clearances shall be maintained from telephone conductors and cables as specified in Section G10.301-S.

3.02 When it is necessary to install power service wire below the communication level, the service terminal shall be located on a crossarm placed for that purpose not less than 48 inches below communication conductors or cable. The service terminal shall be located on the bottom of the crossarm not less than 25 inches from the center line of pole. The lateral and vertical portion of the service run on the crossarm or pole shall be covered as required by the various laws, rules or regulations.

4. DECORATIVE LIGHT STREAMERS

4.01 Light streamers shall be attached to the supporting span wire or messenger between the sectionalizing insulators only and shall not be attached to the span wire between any sectionalizing insulator and the supporting pole.

4.02 All energized portions of streamers and service wires shall have minimum radial clearances from communication cables and conductors in accordance with the provisions of Section G10.301-S.