

DIMENSIONS OF NEW POLES

STUBS AND ANCHOR LOGS

NOTES CONCERNING THIS ADDENDUM

This addendum supplements Section G21.075.1 and has been issued to provide information about the dimensions of Western Larch Poles

Part 6 of G21.075.1 is canceled and should be crossed out and marked "See Addendum."

6. WESTERN LARCH POLES AND STUBS

6.01 In order to comply with the requirements of the California Public Utilities Commission, Western Larch Poles are reclassified locally to the same as Douglas fir, therefore, the dimensions given in Part 6 for Southern Pine and Douglas fir poles should also be used for Western Larch Poles.