

POLE LINES  
INSPECTION 56 L-J

5600 Pound Fibre Strength  
Light Storm Loading Area  
Joint Use Poles

NOTES CONCERNING THIS ADDENDUM

This addendum has been issued to supplement Section G21.356 in order to bring it into conformity with the requirements of the California Railroad Commission.

The cross-reference, "See Addendum," should be marked after Paragraph 2.02 of Section G21.356.

3. LOCAL REQUIREMENTS

3.01 These instructions are for use in locations where trouble has not been experienced as the result of accumulations of sleet, snow or ice.

3.02 A ground line circumference of 12 inches shall be considered to be the "minimum circumference" in all cases where a value of less than 12 inches is shown in the tables of Section G21.356.