

POLE LINES  
INSPECTION 74 L

7400 Pound Fibre Strength  
Light Storm Loading Area  
Toll and Exchange Poles

NOTES CONCERNING THIS ADDENDUM

This addendum has been issued to supplement Section G21.385 in order to bring it into conformity with the requirements of the California Railroad Commission.

The cross-reference, "See Addendum," should be marked after Paragraph 2.02 of Section G21.385 and at Table 74 L-R.

3. LOCAL REQUIREMENTS

3.01 These instructions are for use in locations where trouble has not been experienced as the result of accumulations of sleet, snow or ice.

3.02 A ground line circumference of 12 inches shall be considered to be the "minimum circumference" in all cases where a value of less than 12 inches is shown in Tables 74 L-A, 74 L-B, and 74 L-C of Section G21.385.

3.03 The 74 L-R Table of this Section is hereby cancelled and any inspection of poles under this classification shall be based on the values shown in the 74 L-C Table, as modified by Paragraph 3.02 of this Addendum.